



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2057**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 7/7/25*  
*Time: 3:04 PM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 7/10/25*  
*Time: 9:30 AM*  
*Analyst: AS*

*Facility Name: Brentwood Borough Pool*

*Address: Park Dr.*  
*Pittsburgh, PA 15227*

*Matrix: Recreational Water*

*Source Type: Shallow End*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 4:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/7/25 3:04 PM	SL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/7/25 3:04 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 3:04 PM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2057**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 7/7/25*  
*Time: 3:04 PM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 7/10/25*  
*Time: 9:30 AM*  
*Analyst: AS*

*Facility Name: Brentwood Borough Pool*  
*Address: Park Dr.*  
*Pittsburgh, PA 15227*

*Matrix: Recreational Water*  
*Source Type: Shallow End*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 4:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/7/25 3:04 PM	SL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/7/25 3:04 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 3:04 PM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor