



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 313**

**Customer**

**Facility Name:** UPMC Sports Rehab - Cranberry

**Address:** 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/1/25

**Time:** 11:45 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/4/25

**Time:** 9:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/2/25	10:40 AM	EB	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	7/2/25	10:40 AM	EB	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	7/1/25	5:37 PM	SL	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/2/25	11:40 AM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	11:45 AM	JR	DPD
-----	--------	--------------	--------	----------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	11:45 AM	JR	DPD
-----------	----------	----------------	--------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	7/1/25	11:45 AM	JR	Visual
------------	-------	-----------	--------	----------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 313**

**Customer**

**Facility Name:** UPMC Sports Rehab - Cranberry

**Address:** 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/1/25

**Time:** 11:45 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/4/25

**Time:** 9:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/2/25	10:40 AM	EB	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	7/2/25	10:40 AM	EB	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	7/1/25	5:37 PM	SL	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/2/25	11:40 AM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	11:45 AM	JR	DPD
-----	--------	--------------	--------	----------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	11:45 AM	JR	DPD
-----------	----------	----------------	--------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	7/1/25	11:45 AM	JR	Visual
------------	-------	-----------	--------	----------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor