

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 12

Lab# 2169

7/28/25

Customer Sample Collection Facility Name: Edgewood Club Date:

Time: 1:05 PM 1 Pennwood Ave. Address: Method: Grab

Pittsburgh, PA 15218

Sample Final Analysis Matrix: Recreational Water Date: 7/31/25

Time: 9:00 AM Source Type: Deep End Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 7/29/25 9:10 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 9:10 AM EΒ SM 9222B 7/29/25 2:46 PM Standard plate count: 0/ml 200/ml 7/28/25 EΒ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	1:05 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:05 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:05 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 12

Lab# 2169

7/28/25

Customer Sample Collection Facility Name: Edgewood Club Date:

Time: 1:05 PM 1 Pennwood Ave. Address: Method: Grab

Pittsburgh, PA 15218

Sample Final Analysis Matrix: Recreational Water Date: 7/31/25

Time: 9:00 AM Source Type: Deep End Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 7/29/25 9:10 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 9:10 AM EΒ SM 9222B 7/29/25 2:46 PM Standard plate count: 0/ml 200/ml 7/28/25 EΒ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	1:05 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:05 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:05 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor