



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 162

Customer

Facility Name: *Holiday Inn Express*

Address: *3695 State Rd, RT 31*
Donegal, PA 15628

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/14/25*

Time: *10:00 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/17/25*

Time: *8:30 AM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/15/25 | 10:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/15/25 | 10:15 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/14/25 | 5:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/14/25 | 10:00 AM | JC | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 10:00 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 10:00 AM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 162

Customer

Facility Name: *Holiday Inn Express*

Address: *3695 State Rd, RT 31*
Donegal, PA 15628

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/14/25*

Time: *10:00 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/17/25*

Time: *8:30 AM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/15/25 | 10:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/15/25 | 10:15 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/14/25 | 5:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/14/25 | 10:00 AM | JC | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 10:00 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 10:00 AM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor