# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**S-11**

***Lab# 2321***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Liberty Pointe* | *Date:* | *5/28/25* |
| | | *Time:* | 10:02 AM |
| *Address:* | *35 Highland Rd.* | *Method:* | *Grab* |
| | *Bethel Park, PA 15102* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *5/31/25* |
| | | *Time:* | *9:30 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 11:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 11:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/28/25 | 6:25 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/28/25 | 10:02 AM | CW | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 10:02 AM | CW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 10:02 AM | CW | Visual |

**Sample comments**

Andre Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**S-11**

***Lab# 2321***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Liberty Pointe* | *Date:* | *5/28/25* |
| | | *Time:* | 10:02 AM |
| *Address:* | *35 Highland Rd.* | *Method:* | *Grab* |
| | *Bethel Park, PA 15102* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *5/31/25* |
| | | *Time:* | *9:30 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 11:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 11:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/28/25 | 6:25 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/28/25 | 10:02 AM | CW | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 10:02 AM | CW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 10:02 AM | CW | Visual |

**Sample comments**

Andre Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor