



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2134**

**Customer**

Facility Name: Crafton Borough Pool

Address: 117 W. Steuben St.  
Crafton, PA 15205

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 7/9/25

Time: 9:15 AM

Method: Grab

**Sample Final Analysis**

Date: 7/12/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	3:30 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	3:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	3:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	9:15 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2134**

**Customer**

Facility Name: *Crafton Borough Pool*

Address: *117 W. Steuben St.  
Crafton, PA 15205*

Matrix: *Recreational Water*

Source Type: *Shallow End*

**Sample Collection**

Date: *7/9/25*

Time: *9:15 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/12/25*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	3:30 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	3:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	3:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	9:15 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor