Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 239

Customer		*Sample Collection*	
Facility Name:	Northgate H. S.	*Date:*	6/17/25
		Time:	9:44 AM
Address:	589 Union Ave	*Method:*	Grab
	Pittsburgh, PA 15202		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	6/20/25
		Time:	9:00 AM
Source Type:	Shallow End	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25	9:44 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	9:44 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	9:44 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer		*Sample Collection*	
Facility Name:	*Northgate H. S.*	*Date:*	*6/17/25*
		Time:	*9:44 AM*
Address:	*589 Union Ave*	*Method:*	*Grab*
	Pittsburgh, PA 15202		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/20/25*
		Time:	*9:00 AM*
Source Type:	*Shallow End*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25	9:44 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	9:44 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	9:44 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor