

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 214

Customer

Facility Name:

Liberty Hills

Address:

100 Liberty Lane

Freedom, PA 15042

Matrix:

Source Type:

Recreational Water

Spa

Sample Collection

Date: 7/21/25

Time: Method: 12:18 PM

Grab

Sample Final Analysis

Date:

7/24/25

Time: Analyst: 10:00 AM

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	3:53 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/22/25	12:30 PM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	12:18 PM	ZR	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	12:18 PM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	12:18 PM	ZR	Visual	

Sample comments

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 214

Customer

Facility Name:

Liberty Hills

Address:

100 Liberty Lane

Freedom, PA 15042

Matrix:

Source Type:

Recreational Water

Spa

Sample Collection

Date: 7/21/25

Time: Method: 12:18 PM

Grab

Sample Final Analysis

Date:

7/24/25

Time: Analyst: 10:00 AM

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	3:53 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/22/25	12:30 PM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	12:18 PM	ZR	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	12:18 PM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	12:18 PM	ZR	Visual	

Sample comments

andre Smith