



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2161

Customer

Facility Name: *Eagle Trace*
Address: *300 Allandale Dr.*
Bethel Park, PA 15102

Sample Collection

Date: *6/11/25*
Time: *3:46 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/13/25*
Time: *3:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	5:30 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	5:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	4:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/11/25	3:46 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/11/25	3:46 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	3:46 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2161

Customer

Facility Name: *Eagle Trace*
Address: *300 Allandale Dr.*
Bethel Park, PA 15102

Sample Collection

Date: *6/11/25*
Time: *3:46 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/13/25*
Time: *3:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	5:30 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	5:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	4:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/11/25	3:46 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/11/25	3:46 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	3:46 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor