



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2190

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Forest Glen	Date:	6/24/25
Address:	1514 Forest Green Dr. Moon, PA 15108	Time:	11:30 AM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Wading Pool		

	<u>Sample Final Analysis</u>		
Matrix:	Recreational Water	Date:	6/27/25
Source Type:	Wading Pool	Time:	9:20 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/25/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/24/25	11:30 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/24/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/0/00	11:30 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2190

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>
Facility Name:	Forest Glen	Date: 6/24/25
Address:	1514 Forest Green Dr. Moon, PA 15108	Time: 11:30 AM Method: Grab
Matrix:	Recreational Water	<u>Sample Final Analysis</u>
Source Type:	Wading Pool	Date: 6/27/25 Time: 9:20 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/25/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/24/25	11:30 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/24/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/0/00	11:30 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor