



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 111**

**Customer**

**Facility Name:** Greenfield Elementary

**Address:** 1 Alger St.  
Pittsburgh, PA 15207

**Matrix:** Recreational Water

**Source Type:** Deep End

**Sample Collection**

**Date:** 11/3/25

**Time:** 11:23 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 11/6/25

**Time:** 11:00 AM

**Analyst:** AS

| Accredited Analysis   | Results  | Rating | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|--------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | A      | 11/4/25              | 10:30 AM | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | A      | 11/4/25              | 10:30 AM | JC      | SM 9222B |
| Standard plate count: | 0/ml     | A      | 11/3/25              | 5:30 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Rating | Date/Time |          | Analyst | Method |
|----------------|----------|--------|-----------|----------|---------|--------|
| pH:            | 7.4 SU   | A      | 11/3/25   | 11:23 AM | MM      | DPD    |
| Chlorine:      | 4.0 mg/l | B      | 11/3/25   | 11:23 AM | MM      | DPD    |
| Turbidity:     | 1 NTU    | A      | 11/3/25   | 11:23 AM | MM      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor