Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2307

Customer

		Sample Collection	
Facility Name:	Kiwanis Park Pool	*Date:*	6/30/25
		Time:	8:38 AM
Address:	1 Meyer Rd.	*Method:*	Grab
	Glenshaw, PA 15116		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	7/3/25
		Time:	9:30 AM
Source Type:	Shallow End	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:44 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	8:38 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/30/25	8:38 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	8:38 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2307

Customer		*Sample Collection*	
Facility Name:	Kiwanis Park Pool	*Date:*	6/30/25
		Time:	8:38 AM
Address:	1 Meyer Rd.	*Method:*	Grab
	Glenshaw, PA 15116		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	7/3/25
		Time:	9:30 AM
Source Type:	Shallow End	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:44 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	8:38 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/30/25	8:38 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	8:38 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor