



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2602

Customer

Facility Name:

Woodridge Condos

Address:

100 Woodridge Circle
Pittsburgh, PA 15234

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date: 6/17/25

Time: 4:10 PM

Method: Grab

Sample Final Analysis

Date: 6/20/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25 11:35 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25 11:35 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25 5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25 4:10 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25 4:10 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25 4:10 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2602

Customer

Facility Name:

Woodridge Condos

Address:

100 Woodridge Circle
Pittsburgh, PA 15234

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date: 6/17/25

Time: 4:10 PM

Method: Grab

Sample Final Analysis

Date: 6/20/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25 11:35 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25 11:35 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25 5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25 4:10 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25 4:10 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25 4:10 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor