

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2097**

**Customer**

Facility Name: Chartiers Valley C.C.

Address: 601 Baldwin Road  
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 6/11/25

Time: 9:30 AM

Method: Grab

**Sample Final Analysis**

Date: 6/13/25

Time: 3:00 PM

Analyst: AS


Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25 3:33 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/11/25 9:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25 9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25 9:30 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2097**

**Customer**

Facility Name: Chartiers Valley C.C.

Address: 601 Baldwin Road  
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 6/11/25

Time: 9:30 AM

Method: Grab

**Sample Final Analysis**

Date: 6/13/25

Time: 3:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25 3:33 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/11/25 9:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25 9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25 9:30 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor