



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 117

Customer

Facility Name: Hampton Inn
Address: 1247 Smallman St.
Pittsburgh, PA 15222

Sample Collection

Date: 9/16/25
Time: 10:30 AM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 9/19/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/17/25 9:30 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/17/25 9:30 AM | SL | SM 9222B |
| Standard plate count: | 50/ml | 200/ml | 9/16/25 4:30 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|----------|-----------------|----------------------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 9/17/25 10:00 AM | SL | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 9/16/25 10:30 AM | BH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 9/16/25 10:30 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/16/25 10:30 AM | BH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor