Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

EOP1

Lab# **2025**

Customer			*Sample Collection*	
Facility Name:	*Bairel Center*		*Date:*	*4/28/25*
			Time:	*9:55 AM*
Address:	*2565 Nicholson Road*		*Method:*	*Grab*
	Sewickley, PA 15143			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*5/1/25*
			Time:	*9:00 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/29/25	9:55 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/29/25	9:55 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	4/28/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	4/28/25	9:55 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	4/28/25	9:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/28/25	9:55 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

EOP1

Lab# 2025

Customer

Facility Name:	*Bairel Center*
Address:	*2565 Nicholson Road*
	Sewickley, PA 15143
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*4/28/25*
Time:	9:55 AM
Method:	*Grab*

Sample Final Analysis

Date:	*5/1/25*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/29/25	9:55 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/29/25	9:55 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	4/28/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	4/28/25	9:55 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	4/28/25	9:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/28/25	9:55 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor