

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 11

Lab# 2147

Customer

Facility Name:

Days Inn-Donegal

Address:

Route 31

Donegal, PA 15628

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date:

8/11/25

Time: Method: 9:27 AM Grab

Sample Final Analysis

Date:

8/14/25

Time:

9:00 AM

Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	АН	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	8/11/25	9:27 AM	JC	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	9:27 AM	JC	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	9:27 AM	JC	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 11

Lab# 2147

Customer

Facility Name:

Days Inn-Donegal

Address:

Route 31

Donegal, PA 15628

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date:

8/11/25

Time: Method: 9:27 AM Grab

Sample Final Analysis

Date:

8/14/25

Time:

9:00 AM

Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	АН	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	8/11/25	9:27 AM	JC	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	9:27 AM	JC	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	9:27 AM	JC	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor