# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**C-11**

*Lab# 378*

---

## *Customer*

| | | | *Sample Collection* | |
|---|---|---|---|---|
| *Facility Name:* | *Embassy Suite Hotel - Downtown* | | *Date:* | *7/1/25* |
| | | | *Time:* | 11:05 AM |
| *Address:* | *535 Smithfield St* | | *Method:* | *Grab* |
| | *Pittsburgh, PA 15222* | | | |
| | | | *Sample Final Analysis* | |
| *Matrix:* | *Recreational Water* | | *Date:* | *7/4/25* |
| | | | *Time:* | *9:30 AM* |
| *Source Type:* | *Pool* | | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 7/2/25 | 10:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/2/25 | 10:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/1/25 | 4:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.0  SU | 7.2 - 7.8 SU | 7/1/25 | 11:05 AM | LM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/1/25 | 11:05 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/1/25 | 11:05 AM | LM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

_____

Andre Smith, Lead Supervisor

**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-11**

*Lab#  378*

## B & R Pools and Swim Shop

### Customer

| | |
|---|---|
| *Facility Name:* | *Embassy Suite Hotel -  Downtown* |
| *Address:* | *535 Smithfield St* |
| | *Pittsburgh, PA 15222* |
| *Matrix:* | *Recreational Water* |
| *Source Type:* | *Pool* |

### Sample Collection

| | |
|---|---|
| *Date:* | *7/1/25* |
| *Time:* | 11:05 AM |
| *Method:* | *Grab* |

### Sample Final Analysis

| | |
|---|---|
| *Date:* | *7/4/25* |
| *Time:* | *9:30 AM* |
| *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 7/2/25 | 10:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/2/25 | 10:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/1/25 | 4:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.0  SU | 7.2 - 7.8 SU | 7/1/25 | 11:05 AM | LM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/1/25 | 11:05 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/1/25 | 11:05 AM | LM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

_Andre Smith_

Andre Smith, Lead Supervisor