



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 242

Customer

Facility Name: *Obama High School*
Address: *515 N. Highland Ave*
Pittsburgh, PA 15206

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *1/27/26*
Time: *10:02 AM*
Method: *Grab*

Sample Final Analysis

Date: *1/30/26*
Time: *12:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	1/28/26	11:30 AM	JC	SM 9222G
Total coliforms:	1/100mls	B	1/28/26	11:30 AM	JC	SM 9222B
Standard plate count:	0/ml	A	1/27/26	5:16 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	1/27/26	10:02 AM	MM	DPD
Chlorine:	3.0 mg/l	A	1/27/26	10:02 AM	MM	DPD
Turbidity:	1 NTU	A	1/27/26	10:02 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)