



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
C-2

Lab# 446

Customer

Facility Name: Comfort Inn
Address: 830 East Ohio St.
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/9/25
Time: 12:00 AM
Method: Grab

Sample Final Analysis

Date: 12/12/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/10/25	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/10/25	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	12/9/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	12/9/25	12:50 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/9/25	12:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/9/25	12:50 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor