



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 357

Customer

Facility Name: YMCA - East Suburban

Address: 2200 Golden Mile Hwy.
Plum, PA 15239

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 2/11/26

Time: 12:05 PM

Method: Grab

Sample Final Analysis

Date: 2/13/26

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/11/26	3:24 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/11/26	3:24 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/11/26	3:24 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/11/26	12:05 PM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/11/26	12:05 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/11/26	12:05 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor