Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab# 2666

Customer			*Sample Collection*	
Facility Name:	*Danbury Farms*		*Date:*	*7/28/25*
			Time:	11:45 AM
Address:	*100 Carriage Dr*		*Method:*	*Grab*
	Freedom, PA 15042			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/31/25*
			Time:	*9:00 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	11:45 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:45 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:45 AM	ZR	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab# 2666

Customer		*Sample Collection*	
Facility Name:	*Danbury Farms*	*Date:*	*7/28/25*
		Time:	*11:45 AM*
Address:	*100 Carriage Dr*	*Method:*	*Grab*
	Freedom, PA 15042		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/31/25*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	11:45 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:45 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:45 AM	ZR	Visual

Sample comments

_____

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)