Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

			Sample Collection	
Facility Name:	Residence Inn Cranberry		Date:	6/30/25
			Time:	10:38 AM
Address:	1308 Freedom Rd.		Method:	Grab
	Cranberry, PA 16066			
			Sample Final Analysis	
Matrix:	Recreational Water		Date:	7/3/25
			Time:	9:30 AM
Source Type:	Pool		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/30/25	10:38 AM	ZR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/30/25	10:38 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:38 AM	ZR	Visual

Sample comments

_____

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab#   386

Customer		Sample Collection	
Facility Name:	*Residence Inn Cranberry*	*Date:*	*6/30/25*
		Time:	10:38 AM
Address:	*1308 Freedom Rd.*	*Method:*	*Grab*
	Cranberry, PA 16066		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/3/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/30/25	10:38 AM	ZR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/30/25	10:38 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:38 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)