



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 502

Customer

Facility Name: Hampton by Hilton

Address: 202 Fairview Dr.
Monaca, PA 15061

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 10/13/25

Time: 1:11 PM

Method: Grab

Sample Final Analysis

Date: 10/16/25

Time: 10:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 10/14/25 | 9:30 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/14/25 | 9:30 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/13/25 | 4:15 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 10/13/25 | 1:11 PM | AMH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 10/13/25 | 1:11 PM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/13/25 | 1:11 PM | AMH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor