



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 072**

**Customer**

**Facility Name:** Courtyard by Marriott  
**Address:** 150 Cranberry Woods Dr.  
Cranberry, PA 16066

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 10/27/25  
**Time:** 10:50 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 10/30/25  
**Time:** 12:30 PM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/25	12:00 PM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/25	12:00 PM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/27/25	5:12 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	10/27/25	10:50 AM	BH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	10/27/25	10:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/25	10:50 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor