Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# **000**

Customer

Facility Name:	*Camp Deer Creek*
Address:	*109 Eisele Road*
	Cheswick, PA 15024
Matrix:	*Recreational Water*
Source Type:	*Creek*

Sample Collection

Date:	*7/29/25*
Time:	2:40 PM
Method:	*Grab*

Sample Final Analysis

Date:	*8/1/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Present	Absent	7/30/25	10:00 AM	AH	SM 9222G
Total coliforms:	5/100mls	2/100mls	7/30/25	10:00 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/29/25	2:40 PM	SH	DPD
Chlorine:	NA	1.0 - 5.0 mg/l	7/29/25	2:40 PM	SH	DPD
Turbidity:	2 NTU	1 - 2 NTU	7/29/25	2:40 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Lab# 000

Customer

Facility Name:	*Camp Deer Creek*
Address:	*109 Eisele Road* *Cheswick, PA 15024*
Matrix:	*Recreational Water*
Source Type:	*Creek*

Sample Collection

Date:	*7/29/25*
Time:	2:40 PM
Method:	*Grab*

Sample Final Analysis

Date:	*8/1/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Present	Absent	7/30/25	10:00 AM	AH	SM 9222G
Total coliforms:	5/100mls	2/100mls	7/30/25	10:00 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/29/25	2:40 PM	SH	DPD
Chlorine:	NA	1.0 - 5.0 mg/l	7/29/25	2:40 PM	SH	DPD
Turbidity:	2 NTU	1 - 2 NTU	7/29/25	2:40 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor