



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 505

Customer

Facility Name: *Riverside High School*

Address: *300 Counntry Club Dr.*
Ellwood City, PA 16117

Matrix: *Riverside High School*

Source Type: *Pool*

Sample Collection

Date: *8/27/25*

Time: *9:01 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/30/25*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/28/25	10:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/28/25	10:40 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/27/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/27/25	9:01 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/27/25	9:01 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/27/25	9:01 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor