Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2713

Customer		*Sample Collection*	
Facility Name:	*Summer Hill*	*Date:*	*6/17/25*
		Time:	7:35 AM
Address:	*3800 Shirley Ln.*	*Method:*	*Grab*
	Murrysville PA 15668		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/20/25*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/17/25	7:35 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/17/25	7:35 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	7:35 AM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____
Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2713

Customer

Facility Name:	*Summer Hill*
Address:	*3800 Shirley Ln.*
	Murrysville PA 15668
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/17/25*
Time:	7:35 AM
Method:	*Grab*

Sample Final Analysis

Date:	*6/20/25*
Time:	*9:00 AM*
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/17/25	7:35 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/17/25	7:35 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	7:35 AM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor