



Lab ID No. 02-04041

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

**Service****Lab# 424****Customer**

**Facility Name:** Chatham University  
**Address:** 1 Woodland Rd.  
Pittsburgh, PA 15232

**Matrix:** Recreational Water  
**Source Type:** Pool Deep

**Sample Collection**

**Date:** 12/2/24  
**Time:** 10:10 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/5/24  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/2/24	10:10 AM	MB	DPD
Chlorine:	3.6 mg/l	1.0 - 5.0 mg/l	12/2/24	10:10 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	10:10 AM	MB	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor