



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2231**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 6/17/25*  
*Time: 8:00 AM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 6/20/25*  
*Time: 9:00 AM*  
*Analyst: AS*

*Facility Name: Grandview Pointe*  
*Address: 1411 Grandview Ave.*  
*Pittsburgh, PA 15211*

*Matrix: Recreational Water*  
*Source Type: Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	8:00 AM	LM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/17/25	8:00 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	8:00 AM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2231**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 6/17/25*  
*Time: 8:00 AM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 6/20/25*  
*Time: 9:00 AM*  
*Analyst: AS*

*Facility Name: Grandview Pointe*  
*Address: 1411 Grandview Ave.*  
*Pittsburgh, PA 15211*

*Matrix: Recreational Water*  
*Source Type: Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	8:00 AM	LM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/17/25	8:00 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	8:00 AM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor