



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 13**

**Lab# 2657**

**Customer**

**Facility Name:** Olympic Swim Club  
**Address:** 517 Twin Oaks Dr.  
Pittsburgh, PA 15235

**Sample Collection**

**Date:** 8/12/25  
**Time:** 1:22 PM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 8/15/25  
**Time:** 9:00 AM  
**Analyst:** AS

**Source Type:** Outdoor Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	2:56 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	1:22 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/12/25	1:22 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	1:22 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 13**

**Lab# 2657**

**Customer**

**Facility Name:** Olympic Swim Club  
**Address:** 517 Twin Oaks Dr.  
Pittsburgh, PA 15235

**Sample Collection**

**Date:** 8/12/25  
**Time:** 1:22 PM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Outdoor Pool

**Sample Final Analysis**

**Date:** 8/15/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	2:56 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	1:22 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/12/25	1:22 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	1:22 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor