

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-12

Lab# 2447

Customer

Robinson Twp Pool

Facility Name:

Address:

115 Robinson Pool Lane

McKees Rocks, PA 15136

Matrix:

Recreational Water

Source Type:

Shallow End

Sample Collection

Date:

7/9/25 Time: 7:15 AM

Method:

Grab

Sample Final Analysis

Date:

7/12/25 8:30 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	3:30 PM	ЕВ	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	3:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	3:00 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25	7:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25	7:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	7:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-12

Lab# 2447

Customer

Robinson Twp Pool

Facility Name:

Address:

115 Robinson Pool Lane

McKees Rocks, PA 15136

Matrix:

Recreational Water

Source Type:

Shallow End

Sample Collection

Date:

7/9/25 Time: 7:15 AM

Method:

Grab

Sample Final Analysis

Date:

7/12/25 8:30 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	3:30 PM	ЕВ	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	3:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	3:00 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25	7:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25	7:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	7:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor