



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 348

Customer

Facility Name: Wyndham Grand

Sample Collection

Date: 8/25

Time: 11:45 AM

Method: Grab

Address: 600 Commonwealth Place
Pittsburgh, PA 15222

Sample Final Analysis

Date: 8/25

Time: 8:30 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Spa

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/6/25	8:25 AM	PS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	11:45 AM	LM
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/5/25	11:45 AM	LM
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:45 AM	LM

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 348

Customer

Facility Name: Wyndham Grand

Sample Collection

Date: 8/25

Address: 600 Commonwealth Place
Pittsburgh, PA 15222

Time: 11:45 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/8/25

Source Type: Spa

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/6/25	8:25 AM	PS SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	11:45 AM	LM DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/5/25	11:45 AM	LM DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:45 AM	LM Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor