



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2563**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Waterford Landing*

*Date: 6/16/25*

*Time: 9:07 AM*

*Address: 1200 Landing Ln.*  
*Moon Twp, PA 15108*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/19/25*

*Time: 10:00 AM*

*Source Type: Pool*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25	9:07 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/16/25	9:07 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	9:07 AM	AH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2563**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Waterford Landing*

*Date: 6/16/25*

*Time: 9:07 AM*

*Address: 1200 Landing Ln.*  
*Moon Twp, PA 15108*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/19/25*

*Time: 10:00 AM*

*Source Type: Pool*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25	9:07 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/16/25	9:07 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	9:07 AM	AH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor