



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-3

Lab# 285

Customer

Facility Name: Springhill Suites
Address: 3015 Pittsburgh Mills Blvd.
Tarentum, PA 15084

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/4/25
Time: 9:56 AM
Method: Grab

Sample Final Analysis

Date: 9/6/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/4/25	4:30 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/4/25	4:30 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/4/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/4/25	9:56 AM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	9/4/25	9:56 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/4/25	9:56 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor