

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2750

6/30/25

Customer Sample Collection

Facility Name: Lakemont Farms Date: Time:

Time: 1:00 PM
Address: Lakeview Dr. Method: Grab

Bridgeville, PA 15017

Matrix: Recreational Water Sample Final Analysis

Date: 7/3/25

Source Type: Baby Pool Time: 9:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent 7/1/25 11:00 AM EΒ Absent SM 9222G Total coliforms: 0/100mls 2/100mls 7/1/25 11:00 AM EΒ SM 9222B 6:00 PM SL Standard plate count: 200/ml 6/30/25 SM 9215B 0/ml

| Field Analysis | Results | Reporting limit | I | Date/Time | Analyst | Method |
|----------------|----------|-----------------|---------|-----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/30/25 | 1:00 PM | AF | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 1:00 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 1:00 PM | AF | Visual |

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2750

6/30/25

Customer Sample Collection

Facility Name: Lakemont Farms Date: Time:

Time: 1:00 PM
Address: Lakeview Dr. Method: Grab

Bridgeville, PA 15017

Matrix: Recreational Water Sample Final Analysis

Date: 7/3/25

Source Type: Baby Pool Time: 9:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent 7/1/25 11:00 AM EΒ Absent SM 9222G Total coliforms: 0/100mls 2/100mls 7/1/25 11:00 AM EΒ SM 9222B 6:00 PM SL Standard plate count: 200/ml 6/30/25 SM 9215B 0/ml

| Field Analysis | Results | Reporting limit | I | Date/Time | Analyst | Method |
|----------------|----------|-----------------|---------|-----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/30/25 | 1:00 PM | AF | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 1:00 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 1:00 PM | AF | Visual |

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor