# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
### Laboratory Analysis Report

**Lab ID No. 02-04041**

**W-11**

*Lab#* **2727**

---

*Customer*

| | |
|---|---|
| *Facility Name:* | *Montour CC* |
| *Address:* | *1491 Coraopolis Heights Rd* |
| | *Coraopolis, PA 15108* |
| *Matrix:* | *Recreational Water* |
| *Source Type:* | *Deep End* |

*Sample Collection*

| | |
|---|---|
| *Date:* | *8/12/25* |
| *Time:* | 12:00 PM |
| *Method:* | *Grab* |

*Sample Final Analysis*

| | |
|---|---|
| *Date:* | *8/15/25* |
| *Time:* | *9:00 AM* |
| *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/13/25 | 10:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/13/25 | 10:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/12/25 | 3:10 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/12/25 | 12:00 PM | VH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 8/12/25 | 12:00 PM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/12/25 | 12:00 PM | VH | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andrea Smith*

# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

| **Customer** | | **Sample Collection** | |
|---|---|---|---|
| *Facility Name:* | *Montour CC* | *Date:* | *8/12/25* |
| | | *Time:* | 12:00 PM |
| *Address:* | *1491 Coraopolis Heights Rd* | *Method:* | *Grab* |
| | *Coraopolis, PA 15108* | | |
| | | **Sample Final Analysis** | |
| *Matrix:* | *Recreational Water* | *Date:* | *8/15/25* |
| | | *Time:* | *9:00 AM* |
| *Source Type:* | *Deep End* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/13/25 | 10:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/13/25 | 10:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/12/25 | 3:10 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/12/25 | 12:00 PM | VH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 8/12/25 | 12:00 PM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/12/25 | 12:00 PM | VH | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andrea Smith*