



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 388

Customer

Facility Name: Towne Place Suites
Address: 2020 Cool Springs Dr.
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/8/25
Time: 10:55 AM
Method: Grab

Sample Final Analysis


Date: 9/11/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/9/25 10:15 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/9/25 10:15 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/8/25 5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	9/8/25 10:55 AM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/8/25 10:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/8/25 10:55 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)


Andre Smith, Lead Supervisor