# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Lab ID No. 02-04041

**S-12**

*Lab#  2456*

| **Customer** | | **Sample Collection** | |
| --- | --- | --- | --- |
| *Facility Name:* | *Sandcastles Water Park* | *Date:* | *7/28/25* |
| | | *Time:* | *9:02 AM* |
| *Address:* | *1000 Sandcastle Drive* | *Method:* | *Grab* |
| | *Homestead, PA 15120* | | |
| | | **Sample Final Analysis** | |
| *Matrix:* | *Recreational Water* | *Date:* | *7/31/25* |
| | | *Time:* | *9:00 AM* |
| *Source Type:* | *Dragon's Den* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
| --- | --- | --- | --- | --- | --- | --- |
| Escherichia Coli: | Absent | Absent | 7/29/25 | 10:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/29/25 | 10:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/28/25 | 4:45 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| --- | --- | --- | --- | --- | --- | --- |
| pH: | 7.2  SU | 7.2 - 7.8 SU | 7/28/25 | 9:02 AM | SL | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 7/28/25 | 9:02 AM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/25 | 9:02 AM | SL | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Lab ID No. 02-04041

**S-12**

*Lab#  2456*

| **Customer** | | **Sample Collection** | |
| --- | --- | --- | --- |
| *Facility Name:* | *Sandcastles Water Park* | *Date:* | *7/28/25* |
| | | *Time:* | *9:02 AM* |
| *Address:* | *1000 Sandcastle Drive* | *Method:* | *Grab* |
| | *Homestead, PA 15120* | | |
| | | **Sample Final Analysis** | |
| *Matrix:* | *Recreational Water* | *Date:* | *7/31/25* |
| | | *Time:* | *9:00 AM* |
| *Source Type:* | *Dragon's Den* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
| --- | --- | --- | --- | --- | --- | --- |
| Escherichia Coli: | Absent | Absent | 7/29/25 | 10:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/29/25 | 10:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/28/25 | 4:45 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| --- | --- | --- | --- | --- | --- | --- |
| pH: | 7.2  SU | 7.2 - 7.8 SU | 7/28/25 | 9:02 AM | SL | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 7/28/25 | 9:02 AM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/25 | 9:02 AM | SL | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor