Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer				Sample Collection	
Facility Name:	*Sheraton Inn*			*Date:*	*8/4/25*
				Time:	7:41 AM
Address:	*1160 Thorn Run Road*			*Method:*	*Grab*
	Coraopolis, PA 15108				
				Sample Final Analysis	
Matrix:	*Recreational Water*			*Date:*	*8/7/25*
				Time:	11:20 AM
Source Type:	*Pool*			*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	1:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	1:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	7:41 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	7:41 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	7:41 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2491

B & R Pools and Swim Shop

Customer

Facility Name:	*Sheraton Inn*
Address:	*1160 Thorn Run Road*
	Coraopolis, PA 15108
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*8/4/25*
Time:	7:41 AM
Method:	*Grab*

Sample Final Analysis

Date:	*8/7/25*
Time:	*11:20 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	1:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	1:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	7:41 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	7:41 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	7:41 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor