Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab#   108

Customer

Facility Name:	*Gateway High School*
Address:	*3000 Gateway Campus Blvd.* *Monroeville, PA 15146*
Matrix:	*Recreational Water*
Source Type:	*Deep End*

Sample Collection

Date:	*8/5/25*
Time:	11:03 AM
Method:	*Grab*

Sample Final Analysis

Date:	*8/8/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	11:03 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:03 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:03 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 108

Customer
Facility Name:	*Gateway High School*
Address:	*3000 Gateway Campus Blvd.*
	Monroeville, PA 15146
Matrix:	*Recreational Water*
Source Type:	*Deep End*

Sample Collection
Date:	*8/5/25*
Time:	11:03 AM
Method:	*Grab*

Sample Final Analysis
Date:	*8/8/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	11:03 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:03 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:03 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor