



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 254

Customer

Facility Name: *Peters Twp. High School*

Address: *121 Rolling Hills Dr.
McMurray, PA 15317*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *9/22/25*

Time: *11:23 AM*

Method: *Grab*

Sample Final Analysis

Date: *9/25/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/25	3:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/22/25	11:23 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/22/25	11:23 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/25	11:23 AM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor