



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2478

Customer

Facility Name: Seven Oaks C.C.
Address: 132 Lisbon Road
Beaver, PA 15009

Matrix: Recreational Water
Source Type: Wading Pool

Sample Collection

Date: 6/30/25
Time: 2:40 PM
Method: Grab

Sample Final Analysis

Date: 7/3/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/30/25	2:40 PM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/30/25	2:40 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	2:40 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2478

Customer

Facility Name: Seven Oaks C.C.
Address: 132 Lisbon Road
Beaver, PA 15009

Matrix: Recreational Water
Source Type: Wading Pool

Sample Collection

Date: 6/30/25
Time: 2:40 PM
Method: Grab

Sample Final Analysis

Date: 7/3/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/30/25	2:40 PM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/30/25	2:40 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	2:40 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor