



**1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

CP

Lab# 2471

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:		Schenley		Date:	8/19/25	
Address:		1 Overlook Dr. Pittsburgh, PA 15213		Time:	10:27 AM	
<u>Matrix:</u>				Method:	Grab	
Source Type:		Recreational Water		<u>Sample Final Analysis</u>		
				Date:	8/22/25	
				Time:	9:00 AM	
				Analyst:	AS	
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/20/25	9:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	9:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	3:30 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	8/19/25	10:27 AM	CC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/19/25	10:27 AM	CC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	10:27 AM	CC	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor