



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2684

Customer

Facility Name: Glasshouse
Address: 160 E Station Square Dr.
Pittsburgh, PA 15219

Sample Collection

Date: 8/4/25
Time: 9:15 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 8/7/25
Time: 11:20 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/5/25 11:50 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/5/25 11:50 AM | AH | SM 9222B |
| Standard plate count: | 220/ml | 200/ml | 8/4/25 5:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|----------------|---------|--------|
| pH: | 7.3 SU | 7.2 - 7.8 SU | 8/4/25 9:15 AM | DS | DPD |
| Chlorine: | 1.6 mg/l | 1.0 - 5.0 mg/l | 8/4/25 9:15 AM | DS | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 9:15 AM | DS | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2684

Customer

Facility Name: Glasshouse
Address: 160 E Station Square Dr.
Pittsburgh, PA 15219

Sample Collection

Date: 8/4/25
Time: 9:15 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 8/7/25
Time: 11:20 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/5/25 | 11:50 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/5/25 | 11:50 AM | AH | SM 9222B |
| Standard plate count: | 220/ml | 200/ml | 8/4/25 | 5:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.3 SU | 7.2 - 7.8 SU | 8/4/25 | 9:15 AM | DS | DPD |
| Chlorine: | 1.6 mg/l | 1.0 - 5.0 mg/l | 8/4/25 | 9:15 AM | DS | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 | 9:15 AM | DS | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor