



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 321

Customer

Facility Name: Upper St. Clair Rec.
Address: 1551 Mayview Road
Upper St. Clair, PA 15241

Sample Collection

Date: 12/30/25
Time: 1:24 PM
Method: Grab

Matrix: Recreational Water
Source Type: Leisure Pool Shallow

Sample Final Analysis

Date: 1/2/26
Time: 10:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/31/25 | 10:10 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/31/25 | 10:10 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/30/25 | 4:54 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 12/30/25 | 1:24 PM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 12/30/25 | 1:24 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/30/25 | 1:24 PM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor