

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2083

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Cascade Townhomes

Address: 100 East West Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 8/20/25

 Time:
 4:12 PM

Method: Grab

Sample Final Analysis

Date: 8/22/25

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	5:45 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	5:45 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/20/25	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/20/25	4:12 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/20/25	4:12 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/20/25	4:12 PM	MM	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)