

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Service

Lab# 379

<u>Customer</u> <u>Sample Collection</u>

Facility Name: PPG Paints Arena Date: 12/2/24

Address: 1001 Fifth Ave Time: 11:00 AM Method: Grab

Pittsburgh, PA 15219

Matrix: Recreational Water Sample Final Analysis

Date: 12/5/24

Source Type: Spa Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	12/2/24	11:00 AM	DS	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	11:00 AM	DS	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	11:00 AM	DS	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Service

Lab# 379

<u>Customer</u> <u>Sample Collection</u>

Facility Name: PPG Paints Arena Date: 12/2/24

Address: 1001 Fifth Ave Time: 11:00 AM Method: Grab

Pittsburgh, PA 15219

Matrix: Recreational Water Sample Final Analysis

Date: 12/5/24

Source Type: Spa Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	12/2/24	11:00 AM	DS	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	11:00 AM	DS	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	11:00 AM	DS	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)