



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2028

Customer

Facility Name: Banksville
Address: 1461 Crane Ave.
Pittsburgh, PA 15220

Sample Collection

Date: 6/16/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 10:05 AM | AH | SM 9222G |
| Total coliforms: | 1/100mls | 2/100mls | 6/17/25 | 10:05 AM | AH | SM 9222B |
| Standard plate count: | 110/ml | 200/ml | 6/17/25 | 4:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 6/16/25 | 12:30 PM | WB | DPD |
| Chlorine: | 0.5 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 12:30 PM | WB | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 12:30 PM | WB | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2028

Customer

Facility Name: Banksville
Address: 1461 Crane Ave.
Pittsburgh, PA 15220

Sample Collection

Date: 6/16/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 10:05 AM | AH | SM 9222G |
| Total coliforms: | 1/100mls | 2/100mls | 6/17/25 | 10:05 AM | AH | SM 9222B |
| Standard plate count: | 110/ml | 200/ml | 6/17/25 | 4:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 6/16/25 | 12:30 PM | WB | DPD |
| Chlorine: | 0.5 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 12:30 PM | WB | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 12:30 PM | WB | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor