Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 086

Customer		**Sample Collection**	
Facility Name:	*Devonshire*	*Date:*	*8/4/25*
		Time:	9:54 AM
Address:	*1050 McNeilly Rd.*	*Method:*	*Grab*
	Pittsburgh, PA 15226		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/7/25*
		Time:	11:20 AM
Source Type:	*Pool*	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	9:54 AM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	9:54 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	9:54 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

B & R Pools and Swim Shop

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 086

Customer

Facility Name:	*Devonshire*	
Address:	*1050 McNeilly Rd.*	
	Pittsburgh, PA 15226	
Matrix:	*Recreational Water*	
Source Type:	*Pool*	

Sample Collection

Date:	*8/4/25*
Time:	9:54 AM
Method:	*Grab*

Sample Final Analysis

Date:	*8/7/25*
Time:	11:20 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	9:54 AM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	9:54 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	9:54 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor